



**System No. C-AJ-3243**

T Ratings - 1 Hr

F Rating - 3 Hr



SECTION A-A

- 1. CONCRETE FLOOR ASSEMBLY
- 2. THROUGH PENETRANT
- 3. ABESCO CT 120/R TRANSIT
- 4. CP 310 FR ACRYLIC INTUMESCENT CAULK